



TECHNICAL SPECIFICATION

MODEL	OPENINGS	OPERATING PRESSURE	VOLUME	DIAMETER	HEIGHT OF CYLINDRICAL PORTION	TOTAL TANK HEIGHT	TOTAL HEIGHT OF TANK WITH BASE	WEIGHT OF VESSEL WITHOUT BASE	WEIGHT OF VESSEL WITH BASE	BASE DIMENSIONS				
		(Bar)	(ltrs.) +/- 5%	(mm) +/- 2%	(mm) +/- 5%	(mm) +/- 5%	(mm) +/- 5%	(Kgs) +/- 5%	(Kgs) +/- 5%	SIZE	TYPE	REF. DIM (mm)		
				"A"	"B"	"C"	"D"			inch		"E"	"F"	"G"
1865	4" Top & Bottom	10 Bar	250	475	1350	1645	2060	32.81	38.26	21	Tripod	514	200	280
2162	4" Top & Bottom	10 Bar	310	552	1155	1505	1925	34.26	39.71	21	Tripod	514	200	280
2472	4" Top & Bottom	10 Bar	450	610	1327	1740	2163	42.26	47.96	24	Tripod	586	340	280
3072	4" Top & Bottom	10 Bar	710	770	1313	1815	2225	73.16	80.96	30	Tripod	741	490	310
3672	4" Top & Bottom	10 Bar	1020	927	1266	1856	2281	88.86	105.26	36	Tripod	960	650	360

- NOTES:
1. OPERATING TEMPERATURE RANGE: 1 °C TO 49 °C
 2. LINER MATERIAL: LLDPE
 3. LAMINATE MATERIAL: FRP-EPOXY BASED
 4. NOT TO BE USED FOR PNEUMATIC APPLICATIONS
 5. MINIMUM CLEARANCE OF 4 FEET ON TOP REQUIRED FOR PIPING AND MANEUVRING.

THIS DOCUMENT IS SOLELY THE PROPERTY OF PENTAIR WATER. REPRODUCTION, USE, DISCLOSURE, OR TRANSMISSION OF THIS DOCUMENT OR DETAILS CONTAINED HEREIN, IN PART OR IN WHOLE, IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF PENTAIR WATER. THIS DOCUMENT AND ANY COPIES SHALL BE RETURNED TO PENTAIR WATER UPON WRITTEN REQUEST. DO NOT SCALE DRAWING. DIMS. ARE IN mm.

THIRD ANGLE PROJECTION						VERNA, GOA INDIA		
APPROVALS		DATE		TITLE				
DRAWN AXA		11MAY05		4" TOP-BOTTOM OPENING COMPOSITE TANK				
CHECKED PGS		13MAY05		SIZE B/A3		DWG. NO. 88003		REV. E
APPROVED MD		13MAY05		ECN 2592		SCALE NONE		SHEET 1 OF 1