



R.O. MEMBRANE ELEMENT

IN-RO-4040BW/4040LE/4040XLE



Specifications :

Model		IN-RO-4040BW	IN-RO-4040LE	IN-RO-4040XLE
Performance	Membrane Area	90.4 / 8.4 ft ² / m ²	90.4 / 8.4 ft ² / m ²	90.4 / 8.4 ft ² / m ²
	Salt Rejection	99.5%	99%	98%
	Permeate Flow Rate	2400 / 9.1 (GPD) / (m ³ /d)	2400 / 9.1 (GPD) / (m ³ /d)	2700 / 10.2 (GPD) / (m ³ /d)
Testing Conditions	Solution	2000ppm NaCl	1000ppm NaCl	1000ppm NaCl
	Temperature	25.0±1.0 °C	25.0±1.0 °C	25.0±1.0 °C
	Feed Water pH	7.5±0.5	7.5±0.5	7.5±0.5
	Recovery rate (%)	15.0±1.0	15.0±1.0	15.0±1.0
	Testing Pressure	225/1.55 Psi/Mpa	150/1.03 Psi/Mpa	150/1.03 Psi/Mpa

Available with:

FILTRA CONSULTANTS AND ENGINEERS LTD.

Gala No. 2 & 3, Ground Floor, Neminath Industrial Estate No. 2, Navghar, Vasai (East), Dist.: Palghar - 401 219
Tel.: +91 8691009127/26 Email: filtraw@gmail.com Website: www.ewatertreatmentindia.com

